

## ITEMS TO LOOK FOR DURING ENVIRONMENTAL SAFETY INSPECTION

1.	No penetrations in fire doors or fire walls.
2.	Walls and ceilings in good repair – no peeling paint
3.	Fire doors are not blocked or propped. Fire doors not held open with devices that are not connected to the fire alarm system.
4.	Crawl spaces and non-sprinkled areas do not have combustible items.
5.	Exit doors do not have items placed in front of them. Hallways clear for exiting.
6.	Check drapery for fire rating.
7.	Propane tank.
8.	Door latches engaged.
9.	No extension cords – Surge Strips only. No dangling surge strips No surge strips plugged into each other. No major appliances plugged into surge strips.
10.	Escutcheon plates.
11.	Oxygen signs on doors or frame when oxygen in use.
12.	No open garbage can - Gazebo.
13.	Back flows on sinks with hoses – Housekeeping.
14.	GFI Receptacles.
15.	Handrails tight and in good working order.
16.	No items on floors in Storerooms.
17.	Inspect sprinkler heads for dust/debris.
18.	Damaged outlets and faceplates.
19.	Doors needing self-closing devices.
20.	Appropriate posting of “Exit” and “No Exit” signs.
21.	Obstructions to Fire Extinguishers
22.	Exit signs illuminated – correct egress indicated.